

OSHA CITATIONS  
Repeat Violations 2004

Installation	UIC	Open Conf. Inspection Date	Inspection Type	Violation Type	Standard Cited	Description	NAVOSH Reference	Abatement Date	Max Private Sector Penalty
Bangor Commissary, 2604 Ohio St., Silverdale, WA 98315	3485B 3486B	5/5/2004	Program - Planned	Repeat	1910.303(f)	<b>Electrical-General identification of disconnecting means and circuits</b> - Each disconnecting means required by this subpart for motors and appliances shall be legibly marked to indicate its purpose, unless located and arranged so the purpose is evident. Each service, feeder, and branch circuit, at its disconnecting means or overcurrent device, shall be legibly marked to indicate its purpose, unless located and arranged so the purpose is evident. These markings shall be of sufficient durability to withstand the environment involved.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	6/9/2004	\$70,000