

OSHA Citations  
Other-Than-Serious FY 2004

Installation	UIC	Inspection Date	Inspection Type	Violation Type	Standard Cited	Description	NAVOSH Reference	Abatement Date	Max private sector penalty
U.S. Navy - NUWC, 610 Dowell St, Keyport, WA 90345	00253	3/3/2004	Program planned	Other	1910.303(g)(1)	<b>Working space about electric equipment</b> - Sufficient access and working space shall be provided and maintained about all electric equipment to permit ready and safe operation and maintenance of such equipment.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	3/22/2004	\$7,000
FISC Bangor Submarine Base, Bldg 7000, 7000 Trigger Ave., Silverdale, WA	3485B, 3486B	3/18/2004	Program - Planned	Other	1910.22(a)(2)	<b>Sanitation</b> - The floor of every workroom shall be maintained in a clean and, so far as possible, a dry condition. Where wet processes are used, drainage shall be maintained, and false floors, platforms, mats, or other dry standing places should be provided.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	8/7/2004	\$7,000
FISC Bangor Submarine Base, Bldg 7000, 7000 Trigger Ave., Silverdale, WA	3485B, 3486B	3/18/2004	Program - Planned	Other	1910.101(b)	<b>Compressed gases</b> - The in-plant handling, storage, and utilization of all compressed gases in cylinders, portable tanks, rail tankcars, or motor vehicle cargo tanks shall be in accordance with Compressed Gas Association Pamphlet P-1-1965, which is incorporated by reference as specified in Sec. 1910.6.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	4/15/2004	\$7,000

OSHA Citations  
Other-Than-Serious FY 2004

FISC Bangor Submarine Base, Bldg 7000, 7000 Trigger Ave., Silverdale, WA	3485B, 3486B	3/18/2004	Program - Planned	Other	1910.303(f)	<b>Compressed gases</b> -The in-plant handling, storage, and utilization of all compressed gases in cylinders, portable tanks, rail tankcars, or motor vehicle cargo tanks shall be in accordance with Compressed Gas Association Pamphlet P-1-1965, which is incorporated by reference as specified in Sec. 1910.6.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	8/7/2004	\$7,000
SEAL Beach Naval Weapons Station, 800 Seal Beach Blvd, Seal Beach, CA 90740	47615	4/12/2004	Fatality Investigation of electrocution on high voltage line from bucket truck	Other	1910.269 (j)(2)(iii)	<b>Electrical</b> - If any defect or contamination that could adversely affect the insulating qualities or mechanical integrity of the live-line tool is present after wiping, the tool shall be removed from service and examined and tested according to paragraph (j).	OPNAVINST 5100.23F Chapter 11 Basic Requirements; Chapter 5	7/11/2004	\$7,000
Dept of Defense CNAT 401 Bataan Bldg 89, Rm 220 Corpus Christi, TX 78419	63110	4/26/2004	Program Related	Other	1910.141(a)(3)	<b>Sanitation</b> - All places of employment shall be kept clean to the extent that the nature of the work allows.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	6/15/2004	\$7,000

OSHA Citations  
Other-Than-Serious FY 2004

Dept of Defense CNAT 401 Bataan Bldg 89, Rm 220 Corpus Christi, TX 78419	63110	4/26/2004	Program Related	Other	1910.141(a)(5)	<b>Sanitation Vermin control</b> - Every enclosed workplace shall be so constructed, equipped, and maintained, so far as reasonably practicable, as to prevent the entrance or harborage of rodents, insects, and other vermin. A continuing and effective extermination program shall be instituted where their presence is detected.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	6/29/2004	\$7,000
Dept of Defense CNAT 401 Bataan Bldg 89, Rm 220 Corpus Christi, TX 78419	63110	4/26/2004	Program Related	Other	1910.141(d)(2)	<b>Sanitation</b> - Each lavatory shall be provided with hot and cold running water, or tepid running water.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	6/29/2004	\$7,000
Naval Weapons Station Detach Port Hadlock, WA 98339	48537	4/26/2004	Program- Planned	Other	1910.37(b)(2)	<b>Emergency exits</b> - Each exit must be clearly visible and marked by a sign reading "Exit."	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	5/20/2004	\$7,000

OSHA Citations  
Other-Than-Serious FY 2004

Naval Weapons Station Detach Port Hadlock, WA 98339	48537	4/26/2004	Program-Planned	Other	1910.157 c(1)	<b>Portable Fire Extinguisher</b> - The employer shall provide portable fire extinguishers and shall mount, locate and identify them so that they are readily accessible to employees without subjecting the employees to possible injury.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	5/20/2004	\$7,000
U.S. Navy NASWI Golf Course Maintenance Shop Oak Harbor, WA 98278	00620	4/27/2004	Planned-program related	Other	1910.303(g)(1)(i)	<b>Electrical</b> -Working clearances. The dimension of the working space in the direction of access to live parts operating at 600 volts or less and likely to require examination, adjustment, servicing, or maintenance while alive may not be less than indicated in Table S-1. In addition to the dimensions shown in Table S-1, workspace may not be less than 30 inches wide in front of the electric equipment. Distances shall be measured from the live parts if they are exposed, or from the enclosure front or opening if the live parts are enclosed.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	5/7/2004	\$7,000

OSHA Citations  
Other-Than-Serious FY 2004

NCTAMS LANT DET CUTLER, ME		6/1/2004	Complaint	Other	1910.1020(e)(1)	<b>Access to records</b> - Whenever an employee or designated representative requests access to a record, the employer shall assure that access is provided in a reasonable time, place, and manner. If the employer cannot reasonably provide access to the record within fifteen (15) working days, the employer shall within the fifteen (15) working days apprise the employee or designated representative requesting the record of the reason for the delay and the earliest date when the record can be made available. <b>NOTE:</b> As of October, 2000, the station is no longer being operated by Navy personnel. NCTS Cutler will continue operations at their nearby radio tower site, but with civilian personnel only.	OPNAVINST 5100.23F Chapter 8 Occupational Health	7/29/2004	\$7,000
Naval Facilities Engineering Command, Bldg. 125, San Diego, CA 92135	53824	9/23/2004	Program- Planned	Other	1910.215(a)(4)	<b>Work rests.</b> On offhand grinding machines, work rests shall be used to support the work. They shall be of rigid construction and designed to be adjustable to compensate for wheel wear. Work rests shall be kept adjusted closely to the wheel with a maximum opening of one-eighth inch to prevent the work from being jammed between the wheel and the rest, which may cause wheel breakage. The work rest shall be securely clamped after each adjustment. The adjustment shall not be made with the wheel in motion.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	11/8/2004	\$7,000

OSHA Citations  
Other-Than-Serious FY 2004

Naval Facilities Engineering Command, Bldg. 125, San Diego, CA 92135	53824	9/23/2004	Program-Planned	Other	1910.215(b)(9)	<b>Safety guards</b> - Where the operator stands in front of the opening, shall be constructed so that the peripheral protecting member can be adjusted to the constantly decreasing diameter of the wheel. The maximum angular exposure above the horizontal plane of the wheel spindle of paragraphs (b)(3) and (4) of this section shall never be exceeded, and the distance between the wheel periphery and the adjustable tongue or the end of the peripheral member at the top shall never exceed one-fourth inch.	OPNAVINST 5100.23F Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	11/8/2004	\$7,000
--	-------	-----------	-----------------	-------	----------------	--	--	-----------	---------

**Note:**

The abatement date is established by the OSHA area office. The period of time to abate a hazard is the shortest interval that an employer can reasonably be expected to correct the violation.

The OSHA Act authorizes civil penalties be assessed for each alleged violation. Most Federal agencies are exempt from these fines. Penalties are based on four factors: 1) the gravity of the violation; 2) the size of the business; 3) the good faith of the employer; 4) the employer's history of previous violations.