

OSHA Citations  
 Serious Violations  
 1st and 2nd Qtr FY 2008

Installation	UIC	Open Conf. Inspection Date	Inspection Type	Violation Type	Standard Cited	Description	NAVOSH Reference	Abatement Date	Max Private Sector Penalty
U.S. Navy - Puget Sound Naval Shipyard 1400 Farragut Ave., Bremerton, WA 98314	61015	12/11/2007	Complaint	Serious	1910.303(b)(2)	<b>Electrical Installation and Use.</b> Listed or labeled equipment shall be installed and used in accordance with any instructions included in the listing or labeling.	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	1/11/2008	\$7,000
Naval Facilities Engineering Command, 400 Marshall Rd. Pearl Harbor, HI 96860	62813	1/7/2008	Planned	Serious	1910.22(d)(1)	<b>Walking-Working Surfaces.</b> In every building or other structure, or part thereof, used for mercantile, business, industrial, or storage purposes, the loads approved by the building official shall be marked on plates of approved design which shall be supplied and securely affixed by the owner of the building, or his duly authorized agent, in a conspicuous place in each space to which they relate. Such plates shall not be removed or defaced but, if lost, removed, or defaced, shall be replaced by the owner or his agent.	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	2/29/2008	\$7,000
Naval Facilities Engineering Command, 400 Marshall Rd., Pearl Harbor, HI 96860	62813	1/7/2008	Planned	Serious	1910.178(a)(4)	<b>Powered Industrial Trucks.</b> Modifications and additions which affect capacity and safe operation shall not be performed by the customer or user without manufacturers prior written approval. Capacity, operation, and maintenance instruction plates, tags, or decals shall be changed accordingly.	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	2/29/2008	\$7,000

OSHA Citations  
 Serious Violations  
 1st and 2nd Qtr FY 2008

Naval Base Point Loma, Bldg. 50, SUBASE, San Diego, CA 92106	63406	2/11/2008	Planned	Serious	<b>1910.215(a)(1)</b>	<b>Machine guarding.</b> Abrasive wheels shall be used only on machines provided with safety guards	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	3/14/2008	\$7,000
Naval Base Point Loma, Bldg. 50, SUBASE, San Diego, CA 92106	63406	2/11/2008	Planned	Serious	<b>1910.215(a)(4)</b>	<b>Work rests.</b> On offhand grinding machines, work rests shall be used to support the work. They shall be of rigid construction and designed to be adjustable to compensate for wheel wear. Work rests shall be kept adjusted closely to the wheel with a maximum opening of one-eighth inch to prevent the work from being jammed between the wheel and the rest, which may cause wheel breakage. The work rest shall be securely clamped after each adjustment. The adjustment shall not be made with the wheel in motion.	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	3/14/2008	\$7,000
Naval Base Point Loma, Bldg. 50, SUBASE, San Diego, CA 92106	63406	2/11/2008	Planned	Serious	<b>1910.253(b)(4)(iii)</b>	<b>Welding, cutting and brazing.</b> Oxygen cylinders in storage shall be separated from fuel-gas cylinders or combustible materials (especially oil or grease), a minimum distance of 20 feet (6.1 m) or by a noncombustible barrier at least 5 feet (1.5 m) high having a fire-resistance rating of at least one-half hour.	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	3/14/2008	\$7,000

OSHA Citations  
 Serious Violations  
 1st and 2nd Qtr FY 2008

Naval Base Point Loma, Bldg. 50, SUBASE, San Diego, CA 92106	63406	2/11/2008	Planned	Serious	<b>1910.303(g)(1)(ii)</b>	<b>Electric equipment operating at 600 volts, nominal, or less to ground, space about electric equipment.</b> Working space may not be used for storage. When normally enclosed live parts are exposed for inspection or servicing, the working space, if in a passageway or general open space, shall be suitably guarded.	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	3/14/2008	\$7,000
Naval Base Point Loma, Bldg. 542, SUBASE, San Diego, CA 92106	63406	2/11/2008	Planned	Serious	<b>1910.303(g)(1)(ii)</b>	<b>Electric equipment operating at 600 volts, nominal, or less to ground, space about electric equipment.</b> Working space may not be used for storage. When normally enclosed live parts are exposed for inspection or servicing, the working space, if in a passageway or general open space, shall be suitably guarded.	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	3/25/2008	\$7,000
Naval Base Point Loma, Recycling Center, Bldg. 379, San Diego, CA 92106	63406	2/11/2008	Planned	Serious	<b>1910.178(a)(4)</b>	<b>Powered Industrial trucks.</b> Modifications and additions which affect capacity and safe operation shall not be performed by the customer or user without manufacturers prior written approval. Capacity, operation, and maintenance instruction plates, tags, or decals shall be changed accordingly.	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	3/28/2008	\$7,000

OSHA Citations  
 Serious Violations  
 1st and 2nd Qtr FY 2008

Naval Facilities Engineering Command, Sheet Metal Shop, Bldg 429, Point Loma, San Diego, CA 92106	63406	3/6/2008	Planned	Serious	<b>1910.106(d)(3)</b>	<b>Flammable and combustible liquid storage.</b> Cabinets shall be designed and constructed to limit the internal temperature to not more than 325 deg. F. when subjected to a 10-minute fire test using the standard time-temperature curve as set forth in Standard Methods of Fire Tests of Building Construction and Materials, NFPA 251-1969, which is incorporated by reference as specified in Sec. 1910.6. All joints and seams shall remain tight and the door shall remain securely closed during the fire test. Cabinets shall be labeled in conspicuous lettering, "Flammable - Keep Fire Away."	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	4/7/2008	\$7,000
Naval Facilities Engineering Command, Bldg 538, Point Loma, San Diego, CA 92106	00245	3/6/2008	Planned	Serious	<b>1910.303(g)(1)(ii)</b>	<b>Space about electric equipment.</b> Working space required by this standard may not be used for storage. When normally enclosed live parts are exposed for inspection or servicing, the working space, if in a passageway or general open space, shall be suitably guarded.	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	4/2/2008	\$7,000
Fleet Readiness Center SW, Bldg. 834, Paint Shop, San Diego, CA 92152	00245	3/27/2008	Planned	Serious	<b>1910.159c(8)(iii)</b>	<b>Fire protection.</b> The employer shall assure that sprinklers are protected from mechanical damage.	OPNAVINST 5100.23G Chapter 11, Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	5/20/2008	\$7,000