

OSHA Citations  
Other than Serious  
Through 4th Qtr FY 2007

Installation	UIC	Inspection Date	Inspection Type	Violation Type	Standard Cited	Description	SOH Reference	Abatement Date	Max. Private Sector Penalty
Naval Facilities Engineering Command, PWC Shops, Bldg 42B, Monterey, CA 93934	61014	10/26/2006	Planned	Other	1910.253(b)(4)(iii)	<b>Oxygen storage.</b> Oxygen cylinders in storage shall be separated from fuel-gas cylinders or combustible materials (especially oil or grease), a minimum distance of 20 feet (6.1 m) or by a noncombustible barrier at least 5 feet (1.5 m) high having a fire-resistance rating of at least one-half hour.	OPNAVINST 5100.23G, Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	12/18/2006	\$7,000
Puget Sound Naval Shipyard, 1400 Farragut Ave., Code 106, Bremerton, WA 98314	32416	1/17/2007	Unplanned	Other	1904.39(a)	<b>Reporting a fatality.</b> Within eight (8) hours after the death of any employee from a work-related incident or the in-patient hospitalization of three or more employees as a result of a work-related incident, you must report the fatality/multiple hospitalization by telephone or in person to the Area Office of the Occupational Safety and Health Administration (OSHA) that is nearest to the site of the incident.	OPNAVINST 5100.23G, Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	2/28/2007	\$7,000

OSHA Citations  
Other than Serious  
Through 4th Qtr FY 2007

NCTAMSLANT Detachment, 175 Ridge Rd, Cutler, ME 04626	63038	5/3/2007	Complaint	Other	<b>1910.157(e)(3)</b>	<b>Portable fire extinguishers.</b> The employer shall assure that portable fire extinguishers are subjected to an annual maintenance check. Stored pressure extinguishers do not require an internal examination. The employer shall record the annual maintenance date and retain this record for one year after the last entry or the life of the shell, whichever is less. The record shall be available to OSHA upon request.	OPNAVINST 5100.23G, Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	5/23/2007	\$7,000
NCTAMSLANT Detachment, 175 Ridge Rd, Cutler, ME 04626	63038	5/3/2007	Complaint	Other	<b>1910.335(b)(1)</b>	<b>Electrical safeguards for personnel protection.</b> Safety signs, safety symbols, or accident prevention tags shall be used where necessary to warn employees about electrical hazards which may endanger them.	OPNAVINST 5100.23G Chapter 11. Inspections and Investigations of Workplaces by Federal and State OSH Officials; Chapter 5. Prevention and Control of Workplace Hazards	5/21/2007	\$7,000

**Note:**  
The abatement date is established by the OSHA area office. The period of time to abate a hazard is the shortest interval that an employer can reasonably be expected to correct the violation.

The OSH Act authorizes civil penalties be assessed for each alleged violation. Most Federal agencies are exempt from these fines. Penalties are based on four factors: 1) the gravity of the violation; 2) the size of the business; 3) the good faith of the employer; and 4) the employer's history of previous violations.